



Washington State  
**DEPARTMENT OF  
ENTERPRISE SERVICES**

**Project 23-05-144  
Office of Independent Investigations (OII)  
Thurston County, WA  
Amendment 3  
July 10, 2023**

1. This paragraph documents a follow up question from an interested party and the answer to that question.

**Question:** What are the ceiling height requirements in the 8,720 RSF Conditioned Warehouse space?

**Answer:** The internal clear height in the Vehicle Processing Bay (approximately 1,000 RSF) should be at least 2 feet greater than the height of the roll-up door. A ceiling height of 9 feet or greater would be acceptable in the remainder of the Conditioned Warehouse space.

2. Point of contact for all questions and comments is Phil Person, (360) 407-9315, [phil.person@des.wa.gov](mailto:phil.person@des.wa.gov). E-mail is the preferred method of communications for project related questions and comments.