



We bring our clients' stories to life.

SPOKANE

203 N. Washington
Ste. 400
Spokane, WA
99201
P 509.838.8568

alscarchitects.com

Tri-Cities Readiness Center
Request for Proposals (RFP)
Addendum No. 02
July 09, 2020

RFP – Responses to Questions

- A. The desired surface for military vehicle parking is 8" concrete. Other options will be considered if necessary, to meet the project budget.
- B. There is no fuel storage/dispensing or fuel truck parking on the site.